Sub Divisional Level Water Quality Testing Laboratory
UTTARAKHAND JAL SANSTHAN
HALDWANI , NAINITAL

Name of the Customer/ Organization:	Nancy Convent Senior Secondary School Jeolikote Distt- Nainital	Sample Description	Nancy Convent Senior Secondary School Jeolikote Distt- Nainital
Type of Water (Surface water/Ground water)	Drinking-Water	Start of analysis End of analysis	13-09-2026 14-09-2026
Sample Code:	SDLWQTML/UJS/ NCS-42	Sample collected By	Customer
Sample Receiving Date and Time:	13-09-2026 12:30 PM	Date of Issue Report	15-09-2026

Water Quality Test Report
Testing Details

S.N.	Parameters	Acceptable Limit (As per BIS 10500-2012)	Permissible Limit (in the Absence of alternative source) (As per BIS 10500-2012)	Results
1	Colour (Hazen units)	5	15	1
2	Odour (Agreeable)	Agreeable	Agreeable	Agreeable
3	pH@25*c	6.5 to 8.5	No relaxation	7.30
4	Alkalinity as CaCo3 (mg/l)	200	600	153
5	Turbidity (NTU)	1	5	0.35
6	Total dissolved solid (mg/l)	500	2000	224
7	Chloride (mg/l)	250	1000	16.05
8	Total hardness (mg/l)	200	600	206
9	Calcium(as ca) (mg/l)	75	200	36.8
10	Magnesium (mg/l)	30	100	27.71
11	Total coliform (MPN/100ML)	ABSENT	ABSENT	ABSENT
12	E.Coli (MPN/100ML)	ABSENT	ABSENT	ABSENT

CHEMIST,
(Surendra Singh)
SDLWQTML,
UJS Haldwani (Nainital)

Chemist
Sub Divisional Level
Water Quality Testing & Monitoring Laboratory
UJS- Haldwani (Nainital)

Technical Manager
In-Charge of Laboratory
UJS Haldwani (Nainital)

TECHNICAL MANAGER
Sub Divisional Level
Water Quality Testing
& Monitoring Laboratory
UJS- Haldwani (Nainital)